

Date: _____ Job Name: _____ Mark: _____

Reference: _____ Unit Location: _____ Prepared By: _____

Engineer: _____ Contractor: _____ Approval: _____

Expected Job Date: _____ Notes: _____

UNIT OPTIONS:

- ADA Fan/Light Control
- ClockBox
- Custom Color **Specify Color:** _____
- Test Tank
- Manual Pull Station
- Top Cover
- Make-Up Air Control Module
- Limiting Speed Control Module

DISCONNECT OPTIONS:

- 3/4" NPT Natural Gas
- Electric ***Specify NEMA: 220VAC** = 14-50R 6-20R **120VAC** = 5-15R 5-20R
- Dual Element (includes 3/4" NPT Natural Gas and Electric)
***Specify NEMA: 220VAC** = 14-50R 6-20R **120VAC** = 5-15R 5-20R
- Dual Receptacle ***Specify NEMA: 220VAC** = 6-20R **120VAC** = 5-15R 5-20R

GENERAL FEATURES:

- Wall Mounted
- Pre-Engineered Fire Suppression System
- Variable Fan Speed Control
- Two Step Pre-Suppression
- Plenum Nozzle
- MAIN Power Switch
- Reset Switch
- Light Switch
- Pressure Gauge
- Temperature Switches
- Hard Wired Fuel Source Disconnect
- Dry Alarm Contacts
- On Board Diagnostics
- Status LED
- Trouble Signal
- Service Key
- Audible Buzzer (90dB)
- Service Switch
- Pressure Switch
- Grease Baffle w/ Drip Tray
- ETL/CSA Listed

FEATURES	DESCRIPTION
Compliance	UL300A NSF UL507 NFPA101
Canopy Width	30 Inches
Dimensions In.	29-7/8 x 19-3/8 x 10-1/2
Weight Lbs.	53.4
Voltage / Hz / Amps	120 / 60 / 4
MOCP	15A
Fire Control	Programmable Logic Controller
Tank Type / Pressure / Volume	Stainless Steel / 102+-8% Psi / 1.84 Liters
Venting / Fan Type / Speed	Ducted / Wall Mount / Variable Speed
CFM	172 ~ 522
Min / Max Installation Height	24 / 30 Inches
Duct Collar (In. / mm)	7 / 177.8
Sound Rating	60 / 75 dB
Finish	18 & 20 GA 304 Brushed Stainless Steel
Lighting	(1) Shatter-Proof 60-Watt Bulb
Suppression Agent	Low pH Wet Chemical Amerex 660
No. of Nozzles / Spray	5 / 60 Degree Conical
Actuation Type	Mechanical Fail-Safe
Protection Device / Limit	3 Globe Links / 212°F