


The Micro Switches are illustrated with the switches not engaged. In normal operating mode the NC of the Micro Switches is open and the NO is closed. At Discharge the Micro Switches open the NO and close the NC.

Responsible dep. Denlar Fire Protection	Created JW	Approved GA
 DENLAR FIRE PROTECTION PRE-ENGINEERED RANGE HOODS The World's Only Fail-Safe UL300A Hood	Document type DS-30-D/F Schematic	Document status Active
	Part Number ASY-300001 ASY-300003	LAB-110195 Date of issue 06/12/2020 Rev. 20200212