

NLAR SUBMITTAL DATA SKU: D1030-R-E

**30" PRE-ENGINEERED RANGE HOOD** 


# **BASE MODEL: D1030-R**

Job Name:	Date:		Mark:
Reference:	Unit Location:		Prepared By:
Engineer:	Contractor:		Approval:
Expected Job Date:	Notes	S	
MODEL FAN OPTIONS Integral Fans: F - Recirculating R - Rear I Top Discharging External Fans: FBO - Fan by SELECT OPTIONAL ACCESSORIES		e Fan 🗌 <b>RF</b> - Roof Mo	ounted Fan 🔲 <b>WF</b> - Wall Mounted Fan
ADA: ADA Fan/Light Control		MACM: Make-Up	Air Control Module
CLBX: ClockBox		LSC: Limiting Spe	eed Control Module
CC: Custom Color – (Stainless Standard)	Specify Color:	CLBX-PRO: Cloc	kBox Pro with integrated ADA
TANK-TEST: Test Tank		STROBE: Horn an	nd Light Strobe Alarm
MPK: Manual Pull Station		<b>PD4X:</b> Power Dis	tribution Box
D1030-TC-F/R: Top Cover			
RANGE FUEL SOURCE DISCONNECT OPTIC	•	•	
<b>G:</b> 3/4" NPT Natural Gas (DED Needed if	Electric Components Need		nt (includes 3/4" NPT Natural Gas and Electric) -
to be Controlled on a Gas Range)		O 14-50R,	220VAC O 5-20R, 120VAC
E: Electric -		DRD: Dual Recept	tacle -
O 14-50R, 220VAC O 6-20R, 220	VAC	O 6-20R, 2	20VAC O 5-15R, 120VAC O 5-20R, 120VAC
O 10-50R, 220VAC O 5-20R, 120	VAC		
O 5-15R, 120VAC ELECTRIC NEMA (RECEPTACLE) OPTIONS			
			G
14-50R 10	0-50R 6-20R	5-15R	5-20R
220VAC 50AMP 220VA	C 50AMP 220VAC 20A	MP 120VAC 15AMF	P 120VAC 20AMP
		Co	ontact factory for any special circumstances

## REQUIREMENTS

#### Hood shall:

- Be D1000 Series by DENLAR Fire Protection
- Be wall mounted so that the bottom of the mounting bracket sits 24" to 30" above the range
- Be of stainless-steel construction (#18 & #20 GA, polished 304) with no sharp edges and brushed finish
- Have factory installed fire suppression system
- Have 212° F degree fusible link (30") which will activate the mechanical fire suppression system
- Have wet chemical extinguishing agent: Low PH Amerex
  660 (pressurized potassium citrate / potassium acetate mix)
- Have centrifugal fan with air delivery



- Fan motor shall be permanently lubricated and meet UL507 standard
- Include a power disconnect for gas and/or electric appliances, deactivated at suppression system discharge
- Automatically disconnect range element once a certain preset temperature is reached or under particular predefined events or conditions
- Unit shall have multiple alarm contacts pre-installed (local, remote and trouble alarms) and an audible buzzer
- Lighting shall be by LED bulb





ES



DL1232A 3/2024

FIRE PROTECTION DENLARHOODS.COM




## **BASE MODEL: D1030-R**




#### **GENERAL FEATURES**

- ETL/CSA listed
- 304 Brushed Stainless Steel
- Fail-Safe mechanical actuation
- Two step pre-suppression
- Plenum nozzle
- Main power switch and reset switch
- Service switch




- Pressure gauge
- Temperature switches
- Hard wired fuel source disconnect
- Dry alarm contacts
- On board diagnostics
- Status LED

- Trouble signal
- Service key
- Audible buzzer (90db)
- LED bulb
- Grease baffle with drip tray



#### **REQUIRED FOR ALL MODELS**



The main unit requires clearance to tilt to a 45° degree angle for maintenance purposes





## **SPECIFICATIONS**

Compliance	UL300A, NSF, UL507	
Weight	53.4 lbs	
Mounting Configuration	Wall	
Min / Max Install Height Above Top of Residentail Range / Cook Top	24" - 30"	
Voltage	120 AC	
Phase	1	
Hz	60 Hz	
Amps	3.15 Amps	
Circuit Breaker Size	15-20 Amps	
Operating Current	1.38 Amps	
Fan Operating Current	0.87 Amps	
Output Operating Current	0.25 to 0.5 Amps	
Input Wiring	Power Cord	
Output Wiring	14/2 MC Wire	
Fan Type	Rear Discharging (Fan is Internal)	
МОСР	15 Amps	
Duct Type	See Local Codes	
Fire Control	Programmable Logic Controller	
Tank Type	Stainless Steel	
Tank Pressure	102+-8% Psi	
Tank Volume	1300 mL	
Suppression Agent	Low pH Wet Chemical Amerex 660	
No. of Nozzles / Spray	5 / 60 Degree Conical 3 Globe Links / 212° F	
Protection Device / Limit		













## **BASE MODEL: D1030-R**

## **NOZZLE PLACEMENT**



## **EXHAUST CUTOUT LOCATION**










# **ELECTRIC STOVE POWER SOURCE DISCONNECT: -E (D1000)**


#### **ELECTRIC RECEPTACLE DIMENSIONS**



#### **SPECIFICATIONS**

Models	-E-220 14-50	-E-220 10-50	-E 220 6-20	-E-120 5-20	-E-120 5-15
Weight	5.4 lbs.				
NEMA	14-50R	10-50R	6-20R	5-20R	5-15R
Output Volts	220 AC	220 AC	220 AC	120 AC	120 AC
Output Current	50 Amps	50 Amps	20 Amps	20 Amps	15 Amps
Coil Voltage	120				
Phase	1				
Frequency	60 Hz				
Fuse	0.5 Amps				
Fuse Type	5 X 20mm Cartridge				
Operating Current	0.25 Amps				
Material	Galvanized				
Mounting Type	Surface or flush mount				
Mounting Height			S		

#### **SCHEMATIC**









# FAN: -R (D1000) 30"

## FAN 30" MODEL DIMENSIONS



## **REAR (DISCHARGING) LAYOUT**




## **TOP DISCHARGING MOUNTING BRACKET (D1000-BPSF)**

## **SPECIFICATIONS**

Style	Rear Discharge
Туре	Integral to Hood
Weight	6.25 lbs
Operating Current	0.8 Amps
Voltage	120 AC
Phase	1
Frequency	60 Hz
CFM + -2.5% (Low-High)	139-279
Pressure (In Water)	-0.090.17
dBA (Low-High)	62 - 70
Hood Outlet (Length-Height)	12 in x 3 in
Duct	4-24 in
Fan Inlet	6.5 in (Dia)
Fan Outlet	12 in x 3 in
Control	Electronic Control Module (ECM)
Speeds	Variable

	D1000-BPSF Layout				
1	1 Cut-outs for Wire Entry				
2	2 Mounting Holes				
3	3 Top Mounting Holes				
4	Cut-out for Rear Exhaust Fan				
5	1/4-20 Studs for Securing Hoods to D1000-BPSF				
6	6 Handy Box for Power In and Power Out				
7	Quick Link Safety Cable Holder				




FIRE PROTECTION DENLARHOODS.COM



## **ALARM: INTEGRATED TO D1000**

#### **ALARM LOCATION**




#### **INTERNAL BUZZER SPECIFICATIONS**

Туре	Audible
Decibels	90
Location	Top center of main unit
Activates upon	Tank discharge hose disconnected, low pressure in tank, or high temp fault (190° F at hood)

#### **MAINTENANCE ALARM SPECIFICATIONS**

Туре	Dry Contact
Type of Contacts	Com / NO
Contact Amperage	5 Amps
Location	PLC contacts C0 and Y0
Activates upon	Tank discharge hose disconnected, low pressure in tank, or high temp fault (190° F at hood)

### **MICRO-SWITCH LAYOUT**



#### LOCAL ALARM SPECIFICATIONS

Туре	Dry Contact
Type of Contacts	Com / NO
Contact Amperage	5 Amps
Location	PLC contacts C1 and Y1
Activates upon	Low pressure in tank, and high temp fault (190° F at hood)

## **MICRO-SWITCH SPECIFICATIONS**


Туре	Dry Contact	
Type of Contacts	Com / NO / NC	
Contact Amperage	15 Amps	
Location	Above tank actuation paddle	
Activates upon	Mechanical discharge of the tank	





# **SUPPRESSION TANK: -TANK-FC/SA (D1000)**

#### **UNIT DIMENSIONS**




	1 Tank is Equipped with a Pressure Switch which opens on discha			
	2	Tank is of Stainless Steel Construction.		
3 Visual Pressure Gauge.		Visual Pressure Gauge.		
ſ	4 Discharge Hose with Quick Connect fitting attached.			


## **NOZZLE PLACEMENT (PRE-INSTALLED IN HOOD)**

## **FC SPECIFICATIONS**

Туре	Self Contained Fire Suppression System
Compliance	UL-1995
Mounting Configuration	Integral to the hood
Weight	9.4 lbs
Vessel	Stainless Steel
Chemical Type	Amerex 660
Volume	1300 mL
Chemical Weight	2.2 lbs
Pressure (PSI) +-8%	102 PSI
Height	8 in
Width	6 in



#### **TANK LOCATION**



## SA SPECIFICATIONS

Туре	Self Contained Fire Suppression System	
Compliance	UL-1995	
Mounting Configuration	Integral to the hood	
Weight	9.4 lbs	
Vessel	Stainless Steel	
Chemical Type	Amerex 660	
Volume	1300 mL	
Chemical Weight	2.2 lbs	
Pressure (PSI) +-8%	Charge to 102 PSI on site	
Height	8 in	
Width	6 in	

