

SUBMITTAL DATA SKU: D1036-D-IF-G

36" PRE-ENGINEERED RANGE HOOD

BASE MODEL: D1036-D-IF

Job Name:	Date:		Mark:
Reference:	Unit Location:		Prepared By:
Engineer:	Contractor:		Approval:
Expected Job Date:	Notes	8:	
MODEL FAN OPTIONS			
Integral Fans: F - Recirculating R - Rear D		- F D DE D(M	and a Care WE Mall Managed Care
Top Discharging External Fans: FBO - Fan by	Others Module 🔀 IF - Inlin	ie Fan 🔲 RF - Root Mi	ounted Fan 🔲 WF - Wall Mounted Fan
SELECT OPTIONAL ACCESSORIES ADA: ADA Fan/Light Control		□ MACM: Make Ur	Air Control Module
CLBX: ClockBox			eed Control Module
CC: Custom Color – (Stainless Standard)	Specify Color:		kbox Pro with integrated ADA
TANK-TEST: Test Tank	Specify Color	_	nd Light Strobe Alarm
MPK: Manual Pull Station		PD4X: Power Dis	9
D1036-TC-D: Top Cover		FD4X.1 ower bis	tilibution box
RANGE FUEL SOURCE DISCONNECT OPTIO	NS (CHECK APPROPRIATE RE	PEDTACLE)	
★ G: 3/4" NPT Natural Gas (DED Needed if	- •-	•	nt (includes 3/4" NPT Natural Gas and Electric) -
to be Controlled on a Gas Range)	р	_	220VAC O 5-20R, 120VAC
E: Electric -		☐ DRD: Dual Recep	,
O 14-50R, 220VAC O 6-20R, 220	VAC		220VAC O 5-15R, 120VAC O 5-20R, 120VAC
O 10-50R, 220VAC O 5-20R, 120V		,	
O 5-15R, 120VAC			
ELECTRIC NEMA (RECEPTACLE) OPTIONS			
Y	-50R 6-20R	5-15R	5-20R
	C 50AMP 220VAC 20A	MP 120VAC 15AMI	P 120VAC 20AMP

Contact factory for any special circumstances

REQUIREMENTS

Hood shall:

- Be D1000 Series by DENLAR Fire Protection
- Be wall mounted so that the bottom of the mounting bracket sits 30" to 36" above the range
- Be of stainless-steel construction (#18 & #20 GA, polished 304) with no sharp edges and brushed finish
- Have factory installed fire suppression system
- Have 280° F degree fusible link (36") which will activate the mechanical fire suppression system
- Have wet chemical extinguishing agent: Low PH Amerex
 660 (pressurized potassium citrate / potassium acetate mix)
- Have centrifugal fan with air delivery

- Be ETL listed, tested to UL300A standard
- Fan motor shall be permanently lubricated and meet UL507 standard
- Include a power disconnect for gas and/or electric appliances, deactivated at suppression system discharge
- Automatically disconnect range element once a certain preset temperature is reached or under particular predefined events or conditions
- Unit shall have multiple alarm contacts pre-installed (local, remote and trouble alarms) and an audible buzzer
- Lighting shall be LED bulb













BASE MODEL: D1036-D-IF




GENERAL FEATURES

- ETL/CSA listed
- 304 Brushed Stainless Steel
- Fail-Safe mechanical actuation
- Two step pre-suppression
- Plenum nozzle
- Main power switch and reset switch
- Service switch


- Pressure switch
- Pressure gauge
- Temperature switches
- Hard wired fuel source disconnect
- Dry alarm contacts
- On board diagnostics
- Status LED

- Trouble signal
- Service key
- Audible buzzer (90db)
- LED bulb
- Grease baffle with drip tray

UNIT DIMENSIONS



REQUIRED FOR ALL MODELS



The main unit requires clearance to tilt to a 45° degree angle for maintenance purposes

SPECIFICATIONS

Compliance	UL300A, NSF, UL507,
Weight	56.8 lbs
Min / Max Install Height Above Top of Residentail Range / Cook Top	30" - 36"
Voltage	120 AC
Phase	1
Hz	60 Hz
Amps	3.15 Amps
Circuit Breaker Size	15-20 Amps
Operating Current	2.4 Amps
Fan Operating Current	2.24 Amps
Output Operating Current	0.25 to 0.5 Amps
Input Wiring	Power Cord
Output Wiring	14/2 MC Wire
Fan Type	Inline Fan (Fan is External)
MOCP	15 Amps
Duct Type	See Local Codes
Fire Control	Programmable Logic Controller
Tank Type	Stainless Steel
Tank Pressure	102+-8% Psi
Tank Volume	1300 mL
Suppression Agent	Low pH Wet Chemical Amerex 660
No. of Nozzles / Spray	4 / 60 Degree Conical
Protection Device / Limit	3 Globe Links / 280° F
	<u> </u>

















BASE MODEL: D1036-D-IF

NOZZLE PLACEMENT



TOP DUCTED EXHAUST














GAS POWER SOURCE DISCONNECT: -G (D1000)


GAS VALVE DIMENSIONS



SPECIFICATIONS

Model	D1000-G
Coil Voltage	120 AC
Phase	1
Frequency	60 Hz
Fuse	0.5 Amps
Operating Current	0.25 Amps
Valve Type	2-way
Function	Normally closed
Actuation Type	Direct lift
Coil Type	½" Npt conduit, 18' leads, class F, NEMA 4X
Body Material	Brass
Seal Material	NBR
Orifice Size	7/16"
Port Size	3/4"
Number Of Ports	2
Port Type	NPT
Media	General purpose for air, liquids, and gases
Min. Pressure Differential	0 PSI
Max. Pressure Differential	100 PSI (AC)
Min. Fluid Temperature	0° F
Max. Fluid Temperature	185° F
Flow Coefficient	5 CV


SCHEMATIC





FAN: -D-IF (D1000) 36"

STANDARD INLINE DIMENSIONS




	D1000-BPSI Layout		
	•		
1	Cut-outs for Wire Entry		
2	Mounting Holes		
3	Top Mounting Holes		
4	1/4-20 Studs for Securing Hoods to D1000-BPSI		
5	Handy box for Power In and Power Out		
6	Quick Link Safety Cable Holder		
7	Collar to Attach Duct Work (7" Dia. X 1" Height) (A Minimum of 6" length of 7" Dia. Duct is required before connecting an Increaser/Adapter)		

SPECIFICATIONS

Style	Inline
Туре	Ducted
Weight	10.5 lbs
Operating Current	1.8 Amps
Voltage	120 AC
Phase	1
Frequency	60 Hz
CFM + -2.5% (Low-High)	283 - 474
Pressure (In Water)	-0.230.61
dBA (Low-High)	57 - 69
Hood Outlet (Length-Height)	7 in (Dia)
Duct	35 ft
Fan Inlet	10 in (Dia)
Fan Outlet	10 in (Dia)
Control	Electronic Control Module (ECM)
Speeds	Variable

TOP DISCHARGING MOUNTING BRACKET (D1000-BPSI)









FAN: -D-IF (D1000) 36"

DUCT LOCATION



FRONT (RECIRCULATING) LAYOUT








ALARM: INTEGRATED TO D1000

ALARM LOCATION




INTERNAL BUZZER SPECIFICATIONS

Туре	Audible
Decibels	90
Location	Top center of main unit
Activates upon	Tank discharge hose disconnected, low pressure in tank, or high temp fault (190° F at hood)

MAINTENANCE ALARM SPECIFICATIONS

Туре	Dry Contact
Type of Contacts	Com / NO
Contact Amperage	5 Amps
Location	PLC contacts C0 and Y0
Activates upon	Tank discharge hose disconnected, low pressure in tank, or high temp fault (190° F at hood)

MICRO-SWITCH LAYOUT



LOCAL ALARM SPECIFICATIONS

Туре	Dry Contact
Type of Contacts	Com / NO
Contact Amperage	5 Amps
Location	PLC contacts C1 and Y1
Activates upon	Low pressure in tank, and high temp fault (190° F at hood)


MICRO-SWITCH SPECIFICATIONS

Туре	Dry Contact
Type of Contacts	Com / NO / NC
Contact Amperage	15 Amps
Location	Above tank actuation paddle
Activates upon	Mechanical discharge of the tank



SUPPRESSION TANK: -TANK-FC/SA (D1000)

UNIT DIMENSIONS




1	Tank is Equipped with a Pressure Switch which opens on discharge.	
2	Tank is of Stainless Steel Construction.	
3	Visual Pressure Gauge.	
4	Discharge Hose with Quick Connect fitting attached.	


FC SPECIFICATIONS

Туре	Self Contained Fire Suppression System
Compliance	UL-1995
Mounting Configuration	Integral to the hood
Weight	9.4 lbs
Vessel	Stainless Steel
Chemical Type	Amerex 660
Volume	1300 mL
Chemical Weight	2.2 lbs
Pressure (PSI) +-8%	102 PSI
Height	8 in
Width	6 in

NOZZLE PLACEMENT (PRE-INSTALLED IN HOOD)



TANK LOCATION



SA SPECIFICATIONS

Туре	Self Contained Fire Suppression System
Compliance	UL-1995
Mounting Configuration	Integral to the hood
Weight	9.4 lbs
Vessel	Stainless Steel
Chemical Type	Amerex 660
Volume	1300 mL
Chemical Weight	2.2 lbs
Pressure (PSI) +-8%	Charge to 102 PSI on site
Height	8 in
Width	6 in

